

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1591:142 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Edward Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 FAX (941) 739-4334

DESIGN: Models 1211B, 1212B, 1214B, 5751B, 5756B, 5754B, 5754B-1Z and 5754B-2Z control units. Automatic, manual and waterflow with local, local with shunt, auxiliary and remote station. Refer to listee's data sheet for detailed product description and operational considerations. Various modules may be added to all models to provide specific signaling features:

-031	Remote Station Module
-032	Remote Station Signaling Line Circuit
-033, -034	Municipal Tie Module
-024, -060	Battery Pack

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7165-0073:127 and 7165-1388:128

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 23, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager